



WO: [8250](#) Stormwater Pipe Illicit Discharge

FIELDS, ROGER

OPEN

220 S. Hall Road , Zips Car Wash

6/17/2021 2:38:04PM | ROGER FIELDS

at 2pm the stromwater crew reported a possible illicit discharge. upon

6/17/2021 2:44:24PM | ROGER FIELDS

the carwash drain was clogged and overflowing into an area drain in the parking lot. I tracked the pink tinted water from there down stream to the 72" outfall behind Midland Shopping Center. The water was still tinted pink from the soap. I spoke with Tory Eisele the site manager, and let him know what was goin on and that the car wash had to be shut down until the drain was repaired and functioning properly. This is a first offense at this location. I am going to prepare an NOV as a response to this incident. Mr. Eisele is going to document the repairs that are carried out.

6/18/2021 10:14:59AM | ROGER FIELDS

Drafted an NOV for Zips carwash, one to be hand delivered locally and the other going to corporate office by certified mail. Also received pictures of repairs that were done to the Carwash and added them below.

6/18/2021 10:55:13AM | ROGER FIELDS

On my follow up visit Mr. Eisele had a maintenance crew on site that did repair a drain filter and was in the process of conducting an inspection of the rest of the system.

ATTACHMENT : 09886269-ED9B-482E-88A9-2628ACEAAF4E.jpeg

ATTACHMENT : 17B268C9-11F3-49E6-ADBC-471D5A780792.jpeg

ATTACHMENT : 2.jpg

ATTACHMENT : 22BCFD76-224B-45D2-B940-CD51D5F82FA6.jpeg

ATTACHMENT : 3.jpg

ATTACHMENT : 4.jpg

ATTACHMENT : 5.jpg

ATTACHMENT : 8BA34C41-230B-4C46-ADB9-99FAAA2B97B6.jpeg

ATTACHMENT : 9A9E313E-18EA-4462-9196-17DCD07C0425.jpeg

ATTACHMENT : A923D971-2060-4913-BE80-932D05E82B3C.jpeg

ATTACHMENT : D7329271-F41C-4051-8FE9-EC24831D6637.jpeg

ATTACHMENT : E4333729-F0E9-42C2-93AE-B47792829C1C.jpeg

ATTACHMENT : Zips carwash.jpg

ATTACHMENT : Zips NOV.pdf

WO: [7837](#) Stormwater Illicit Discharge

FIELDS, ROGER

OPEN

4141 S. Singleton Statinon Road , Project Pearl

6/4/2021 9:23:17AM | ROGER FIELDS

Multiple reports of sediment being tracked onto Singleton Station Road.

---

WO: [7343](#) Stormwater Illicit Discharge

FIELDS, ROGER

4/19/2021 7:26:27AM

CLOSED

933 Cherry Street , 933 Cherry Street

3/24/2021 9:37:58AM | ROGER FIELDS

I went to inspect the complaint and found what appeared to be an oil stain in front of a car that was parked on the curb. I could not tell weather it leaked from the car or was spilled. Just from the size of the stain, it did not appear that the oil was just drained onto the street. See photo below. Oil only ran a short distance and has soaked into the pavement. I will send the resident a written warning.

4/12/2021 9:21:11AM | ROGER FIELDS

Prepared letter to be sent.

ATTACHMENT : 933 Cherry Street complaint (2).jpg

ATTACHMENT : 933 Cherry Street Illicit Discharge Report.pdf

ATTACHMENT : IMG\_6289.jpg

ATTACHMENT : Notice of Violation at 933 Cherry Street.pdf

---

WO: [7181](#) Stormwater Pipe Illicit Discharge

FIELDS, ROGER

3/30/2021 8:14:52AM

CLOSED

140 Cusick Rd , Comfort Suites at 140 Cusick Road

2/23/2021 1:00:09PM | ROGER FIELDS

John Clay called me after lunch about a hotel draining their pool into the street, which leads to the cities storm drain that goes into Russell Branch. I ask him if he would check into it and he found a tech from Sparkle Pools draining the pool and/or hot tub. John Clay noticed a strong Chlorine smell and let the gentleman know that draining Chlorinated water into the storm sewer system is an illicit discharge. The tech said it did not have chlorine in it. John Clay went back with his test kit and did find that it had 1.9 ppm of Chlorine. Derrick Bryant was with John Clay the whole time. Once I had all the information from John Clay, I made a call to Sparkle Pools and spoke with Sierra. I explained the situation to her and let her know that it is a violation of the cities storm water regulations. I am going to email her a copy of the corresponding regulations for their records.

A verbal warning has been issued to Sparkle Pools.

ATTACHMENT : Pool Draining.msg

---

WO: [7160](#) Stormwater Structure Illicit Discharge

FIELDS, ROGER

3/30/2021 8:15:35AM

CLOSED

Hunters Meadow , Hunters Meadow

2/18/2021 7:42:06AM | ROGER FIELDS

A pool contractor displaced a large amount of soil into the street.

2/18/2021 8:01:01AM | ROGER FIELDS

Nathan at Premier Pools moved soil from the lot he was working at down the street to a vacant lot. They did this using a skid steer on the public road. This created a significant amount of soils in the road. I spoke with Nathan and the general contractor building the homes in this subdivision. I told both that if the city has to clean it up before the incoming weather, they will be financially responsible for that clean up.

When I last spoke to Nathan, he was leaning on having the city do the work. I then called Andy Davis and had him call Nathan. The City did the clean up and we will be charging Nathan. I will issue an NOV to the contractor as well.

2/18/2021 8:48:28AM | DAVID SPARKS

Used crusher run to dump on mud to help clean it off. Then washed street.

2/18/2021 2:13:56PM | ROGER FIELDS

Code the invoice to go to 413-35410

2/19/2021 7:06:14AM | ROGER FIELDS

Nathan Hodges  
729 Hidden Glen LN  
Knoxville, TN 37922

- ATTACHMENT : 06B76E03-CC4C-4675-A0B6-D1D2076A97F4.jpeg
- ATTACHMENT : 0A2A2424-08C6-4776-BB1A-E4AA50276B6A.jpeg
- ATTACHMENT : 0B4D2800-D4F8-4129-B00D-206ECA9F8331.jpeg
- ATTACHMENT : 1B506C2E-5E01-4A98-A883-AABA68C30D2A.jpeg
- ATTACHMENT : 2427940D-75CF-40B1-8A56-83547F76E140.jpeg
- ATTACHMENT : 28B23F15-9470-492A-834A-56D83DC200F3.jpeg
- ATTACHMENT : 28E141AB-1B9B-441A-9146-BB52DB0E2624.jpeg
- ATTACHMENT : 3FC0D207-E747-46D9-8307-C2ACF3C28AD2.jpeg
- ATTACHMENT : 472D87A0-38E2-4090-BA92-5431B6DDA4C1.jpeg
- ATTACHMENT : 5F2C50C9-E784-4FCF-AF73-91DC2EA86A59.jpeg
- ATTACHMENT : 7E14A9A6-D524-4C3F-9DEB-305B2E0C1A09.jpeg
- ATTACHMENT : 841D54A4-6F95-4F41-A9EE-EB0935259C44.jpeg
- ATTACHMENT : 95E1BE05-3E70-4FB6-B0C2-0F5C7A841071.jpeg
- ATTACHMENT : 9E09B43F-CD0A-4C0C-8043-7D262036B649.jpeg
- ATTACHMENT : A42419D3-99EF-4CA9-9D98-16F2412428ED.jpeg
- ATTACHMENT : AD21FB9E-3029-4A6A-B13C-4E807AF7DEB0.jpeg
- ATTACHMENT : AF9FBE9D-8A72-4F42-B206-A63ADA335E05.jpeg
- ATTACHMENT : B86EA781-BE34-42E5-8869-CC2E61476BC3.jpeg
- ATTACHMENT : C7299804-B8DD-4527-A7E6-95548BD544F5.jpeg
- ATTACHMENT : CC5FF4B3-27D0-4BB3-8A7A-B2F8708B130B.jpeg
- ATTACHMENT : D4519D19-C30B-410F-909A-5587AC8CB858.jpeg
- ATTACHMENT : DF0A33A2-7038-46C3-93A1-CDD5EE07E370.jpeg
- ATTACHMENT : ED80792C-0815-4625-B008-AD33B57BF261.jpeg

WO: [7046](#) Ditch Illicit Discharge

FIELDS, ROGER

2/15/2021 8:04:44AM  
CLOSED

19-043 - Hamilton Crossing Drive - Culver's Restaurant

2/3/2021 9:14:05AM | ROGER FIELDS

On 2/2/2021 a the waterline providing service to this site was damaged. This caused the trench for the line to be washed out into W. Bessemer St. and into a couple of catch basins. The City of Alcoa Crews responded to the break and cleaned up the site, including the catch basins. I will add the charges to this work order once they have been issued.

2/15/2021 8:04:24AM | ROGER FIELDS

find the invoice being billed to the Culvers contractor for the clean up of the erosion from the fire line break. It is in the Culver's clean up file below.

- ATTACHMENT : Culver's NOC.pdf
- ATTACHMENT : Grading permit.pdf
- ATTACHMENT : Precon for Culver's.pdf
- ATTACHMENT : FW Culver's Cleanup.msg
- ATTACHMENT : Redline.jpg
- ATTACHMENT : Sewer - TDEC Approval Letter WPN 19-0566.pdf
- ATTACHMENT : Sewer - TDEC Approved Plan WPN 19-0566.pdf

---

WO: <a href="#">6081</a> Stormwater Illicit Discharge	FIELDS, ROGER	8/17/2020	1:27:46PM
111 W. Bessemer , Black Horse Brewery			CLOSED

8/17/2020 1:27:42PM | ROGER FIELDS

I made a site visit to follow up on a report from a city employee about dumping into the drainage ditch at the back of the brewery. There were two trailers out back that contains the old fermented grains from the breweries production. I ask a gentleman that works there if he knew of these being dumped into the ditch and he said that they do not. I informed him that such activity would be an illicit discharge that could result in fines from \$50 to \$5k per day. There was some evidence that it has happened, so this is to serve as their verbal warning.