

## **ADDENDUM NO.2**

**Gresham Smith Project Number 47653.02  
City of Alcoa**

### **Werner Avenue Drainage Infrastructure Alcoa, TN**

**December 2nd, 2025**



**Gresham  
Smith**

**Telephone: 865/521-6777  
2095 Lakeside Centre Way,  
Suite 120  
Knoxville, Tennessee 37922**

This Addendum forms as part of and modifies the Contract Documents for City of Alcoa Job# 25-013. Acknowledge the receipt of this Addendum by attaching to the bid documents and initialing the bid form in the space provided. Failure to do so may subject the Bidder to disqualification.

**REFER TO PROJECT MANUAL:**

**BID FORM:**

No changes

**SHEETS:**

Plan Sheets: No Changes

**CLARIFICATION:**

N/A

**QUESTION AND ANSWER:**

Question 1: Are storm structures required to be TDOT certified structures?

**Answer: All structures are to be fabricated to TDOT standard specifications and standard drawings. If precast structures are used, they must be provided by a TDOT prequalified precast producer.**

**LIST OF ATTACHMENTS**

N/A

END OF ADDENDUM NO. 2